

ADDENDUM # 2

Date: March 24, 2023
To: All Bidders of Record

PROJECT:
2023 ROOF REPLACEMENT – TERRACE SPORTSPLEX
ITT #PRC – 02 - 2023

This addendum overrides all information in original specs and drawings.

(1)
UNDER:

TECHNICAL SPECIFICATIONS

PART 2 – PRODUCTS: 2.1 MATERIALS

Remove 1. And Replace with the following:

1. **Asphalt Overlay Board (Asphaltic core board):** Shall be a semi-rigid protection board with a fortified Asphaltic core between fiberglass reinforcing mats, min. 3/16” thickness. It can have the factory applied 180 base sheet installed (or not). Std of acceptance: Sopraboard or 2-1 Soprasmart board (thermal) by Soprema; Protectoboard or Protectobase 180 by IKO

*****END OF ADDENDUM # 1*****